



Ecoglo G20 EVAC Signs are designed to highlight the emergency evacuation plan of the building and to be readable in case of power failure.

SIGN DEFINITION

Emergency Evacuation Plan

COMPLIANCE

Ecoglo G20 EVAC Signs meet luminance specifications of internationally accepted UL 1994 Standard for Luminous Egress Path Marking Systems. The sign is compliant with SECTION 10.2.5.13 of the Fire Code of the Philippines, Revised 2019.

PERFORMANCE

The signs will be operational for up to 90 minutes after failure of the main lighting provided they have been continuously illuminated by a reliable light source with a minimum of 100 lux.

SUPPLY

The sign is available in the sizes below.

PRODUCT CODE	PRODUCT NAME	SIGN DEFINITION	SIGN SIZE
G20-EVAC216330	Evacuation Map	Emergency Evacuation Plan	216mm x 330mm
G20-EVAC457610	Evacuation Map	Emergency Evacuation Plan	457mm x 610mm
G20-EVAC610914	Evacuation Map	Emergency Evacuation Plan	610mm x 914mm

Note: All finished artwork must be submitted in PDF or vector format when ordering the sign.

COMPOSITION

The high visibility flat panel is manufactured from rigid photo-luminescent PVC sheet with a clear acrylic overlay.

INSTALLATION

Metal stand-off fixers (supplied) are the main method of installation, however, please consult Ecoglo for other fixing methods if required.

Contact

Ecoglo Customer Service

Email: InfoPHL@ecoglo.com

Customer Service Cell: +63 917 545 0090 (call / text / whatsapp / viber)

Operations & Administration Landline: +63 2 8802 4760

Website: www.ecoglo.ph