Product Data Sheet - Directional Pictogram Left Facing RML

2023 V1





Ecoglo S5 "Directional Pictogram Left Facing" signs are designed to be clearly visible to persons approaching the exit for compliance with NFPA 101 Life Safety Code and International Fire Code (IFC). The signs will be clearly visible and readily understandable under all conditions of foreseeable use, including emergency conditions.

SIGN DEFINITION

Exit straight on from here.

COMPLIANCE

Ecoglo S5 "Directional Pictogram Left Facing" signs meet ASTM E 2072 requirements and are NFPA 101 Life Safety Code and IFC compliant.

PERFORMANCE

A charging source of 1 ft-candle (11 lux) of fluorescent illumination is necessary for 60 minutes to ensure that minimum luminance requirements of 30 mcd/m2 at 10 minutes and 5 mcd/m2 at 90 minutes are met after failure of the main lighting.

Operating Temperature Range: +10°C to +30°C

UV Resistance – Loss of luminance after 1000 hrs ASTM G-155

Cycle 1 exposure: <10%

Salt Spray Resistance – ASTM B117: Pass

Washability - ASTM D4828: Pass

Rate of Burning - ASTM D635: Pass

Surface Flammability – ASTM E162: Pass

Toxicity - Bombardier Toxic Gas Generation Test SMP800-C: Pass

Radioactivity – ASTM D3648: Pass High Temperature Curing: Pass

SUPPLY

The product is available in the following size. (The sign can be used alone or in combination with Ecoglo directional arrow signs.)

PRODUCT	PRODUCT	SIGN	SIGN SIZE
CODE	NAME	DEFINITION	
S5-RML1010	Directional Pictogram Left Facing	Exit straight on from here	100mm x 100mm

COMPOSITION

The high visibility flat panel is manufactured from 5005 0.9mm aluminium sheet. Custom made photoluminescent pigments are embedded in thermoset polyester carriers to integrally bond the active ingredients onto the aluminium sheet following curing at high temperature.

INSTALLATION

The sign is supplied with pre-fitted release tape for fixing flat on a wall or door.

Contact

Ecoglo Fire Protection Product Trading

Address: 36-C Gloria Street, Barangay San Carlos,

Binangonan Rizal 1940, Philippines

Office: +632-8802-4760 **Cell:** +63917-514-6803 +63968-356-4773

Email: keith.phillips@ecoglo.com
Web: www.ecoglo.ph www.EcogloAsia.com www.EcogloVenues.com