
# Product Data Sheet - Pictogram Up Right Arrow RMUR

2023 V1



Ecoglo S5 "Pictogram Up Right Arrow" signs are designed to be clearly visible to persons approaching the exit for compliance with NFPA 101 Life Safety Code and International Fire Code (IFC). The signs will be clearly visible and readily understandable under all conditions of foreseeable use, including emergency conditions.

#### SIGN DEFINITION

Exit up right from here.

#### COMPLIANCE

Ecoglo S5 "Pictogram Up Right Arrow" signs have been tested to UL 1994 specifications to meet NFPA 101 and IFC.

#### PERFORMANCE

A charging source of 1 ft-candle (11 lux) of fluorescent illumination is necessary for 60 minutes to ensure that minimum luminance requirements of 30 mcd/m2 at 10 minutes and 5 mcd/m2 at 90 minutes are met after failure of the main lighting.

Operating Temperature Range: +10°C to +30°C

UV Resistance – Loss of luminance after 1000 hrs ASTM G-155 Cycle 1 exposure: <10% Salt Spray Resistance – ASTM B117: Pass Washability – ASTM D4828: Pass Rate of Burning – ASTM D635: Pass Surface Flammability – ASTM E162: Pass Toxicity – Bombardier Toxic Gas Generation Test SMP800-C: Pass Radioactivity – ASTM D3648: Pass Radioactivity – ASTM D3648: Pass High Temperature Curing: Pass

#### SUPPLY

The product is available in the following size.

PRODUCT CODE	PRODUCT NAME	SIGN DEFINITION	SIGN SIZE
S5-RMUR2010	Pictogram Up Right Arrow	Exit up right from here	200mm x 100mm

**VISIBLY BETTER** 

#### COMPOSITION

The high visibility flat panel is manufactured from 5005 0.9mm aluminium sheet. Custom made photoluminescent pigments are embedded in thermoset polyester carriers to integrally bond the active ingredients onto the aluminium sheet following curing at high temperature.

#### INSTALLATION

The sign is supplied with pre-fitted release tape for fixing flat on a wall or door.

### Contact

## **Ecoglo Fire Protection Product Trading**

Address: 36-C Gloria Street, Barangay San Carlos, Binangonan Rizal 1940, Philippines Office: +632-8802-4760 Cell: +63917-514-6803 +63968-356-4773 Email: keith.phillips@ecoglo.com Web: www.ecoglo.ph www.EcogloAsia.com www.EcogloVenues.com