

Rapid Spec

Ecoglo Photoluminescent Emergency Evacuation Plans

A) DESCRIPTION

This document is to assist with specification and procurement of high luminance evacuation maps which can be used to meet Emergency Evacuation Plan requirements of The Fire Code of the Philippines.

Ecoglo evacuation maps are available in different dimensions to meet Fire Code of the Philippines specifications.

This document is offered as a guide to experienced and knowledgeable construction professionals who assume full responsibility for its interpretation and use.

B) WORKS SUMMARY

Evacuation Maps

C) WARRANTY

Three (3) years from the date of installation for Evacuation Maps which are positioned indoors.

D) PRODUCTS

Evacuation Map

High Luminance - YES

Product Codes

G20-EVAC216330

G20-EVAC457610

G20-EVAC610914

E) TESTING NOTES

Luminance

The material used in the manufacture of Emergency Evacuation Plans shall meet luminance specifications of UL 1994 Standard for Safety Luminous Egress Path Marking Systems.

Pass criteria:

After charging ceases, minimum luminance readings of 30mcd/m² at 10 minutes, and 5mcd/m² after 90 minutes.